

Combining Web SCADA Software and Matlab-Simulink for Studying Wind-PV-Battery Power Systems

Aryuanto Soetedjo¹, Abraham Lomi², Yusuf Ismail Nakhoda³ and Yohan Pramono Tosadu⁴

¹ Electrical Engineering Department, National Institute of Technology (ITN)
Malang, Indonesia

² Electrical Engineering Department, National Institute of Technology (ITN)
Malang, Indonesia

³ Electrical Engineering Department, National Institute of Technology (ITN)
Malang, Indonesia

⁴ Electrical Engineering Department, National Institute of Technology (ITN)
Malang, Indonesia

Abstract

This paper presents a Web-based SCADA connected to the hybrid power system simulated using Matlab-Simulink. The proposed Web SCADA controls the hybrid power system by connecting/disconnecting the renewable energy resources and load to the bus. It monitors the environment conditions, such as solar irradiation, temperature of PV module, wind speed, and electrical parameters (current, voltage, and power) of hybrid power system. The communication between SCADA server and Simulink model is performed by serial communication using Modbus protocol. The experimental results show that the proposed system achieved the goal, i.e. allowing the Web SCADA system to access the simulated hybrid power system modeled by Simulink in real time.

Keywords: Web SCADA, wind power, PV, hybrid power system, Simulink, Modbus.

1. Introduction

Recently, the development and exploration of the renewable energy resources increase significantly. Among them, the wind and solar power systems are the most popular ones, due to their availability. The prominent characteristic of those power systems is the location dependent, in the sense that the wind power plant should be installed in the place where there is enough wind speed, while the solar power plant requires large space to absorb the sun energy. Usually they are installed in rural area and located separately. Therefore it requires a SCADA (Supervisory Control and Data Acquisition) system to monitor and control them remotely [1-5].

In [1], they proposed a SCADA system to monitor the real-time electrical data of wind-PV-battery renewable

energy system. In the system, a PLC (Programmable Logic Controller) and digital power meters are employed as remote controller and measurement devices. The data from remote devices are sent to the monitoring center using intranet. A SCADA system is used to monitor and detect the failure of wind turbine [2]. The wind turbine failure is detected by observing the anomaly data from several measurements. In [3], they presented the SCADA system used to monitor and control both individual wind turbine and whole wind farm. With SCADA, user might modify the parameters of wind energy converter and voltage control system which are important to optimize the power system operation. In [4], the SCADA is developed for sun-tracker system, which enables the operator to view the actual position of the tracker system and the actual solar power.

Due to the rapid development in IT fields, especially Internet, the web-based automation becomes a recent development in the industry [5]. Web SCADA is one of the web-based automation which utilizes Internet to supervise and monitor the remote devices. The advantages of Web SCADA are [6] : a) Easy to operate using the standard browser navigation tools; b) The implementation cost will generally lower than the traditional one.

This paper describes a novel method to combine a Web SCADA software (IntegraXor[7]) and the popular simulation software (Matlab-Simulink) for studying the wind-PV-battery power system. Instead of using the real power plants, the Simulink model of hybrid power system is modeled and connected to the SCADA software via serial connection. The Modbus protocol is employed for communicating the SCADA and Simulink. In the

proposed system, the Web SCADA works in the normal operation, while the parameters of hybrid power system could be changed easily by Matlab-Simulink. The control operation of Web SCADA is also simulated in the Simulink model.

The rest of paper is organized as follows. Section 2 presents the proposed system consists of the model of hybrid power system and the design of Web SCADA. Section 3 discusses the experimental results. Finally, conclusion is covered in section 4.

2. Proposed System

2.1 Wind Power, PV, and Battery Modeling

Wind power system consists of a wind turbine, a permanent magnet synchronous generator (PMSG), and a three phase rectifier. The power absorbed by wind turbine depends on the wind velocity and expressed as [8]:

$$P = \frac{1}{2} C_p(\lambda, \beta) \rho A v^3 \quad (1)$$

While the torque of wind turbine is expressed as [8]:

$$T = \frac{1}{2} C_t(\lambda, \beta) \rho A R v^2 \quad (2)$$

where

ρ is the air density

A is the swept area of the rotor blade

v is wind velocity

$C_t(\lambda, \beta) = C_p(\lambda, \beta) / \lambda =$ the torque coefficient

β = pitch angle

λ = tip speed ratio

The PMSG is modeled by the differential functions and expressed as [8]:

$$\dot{i}_q = -\frac{R_s}{L} i_q - \omega_e i_d + \frac{\omega_e \phi_m}{L} - \frac{v_s i_q}{L \sqrt{i_q^2 + i_d^2}} \quad (3)$$

$$\dot{i}_d = -\frac{R_s}{L} i_d - \omega_e i_q - \frac{v_s i_d}{L \sqrt{i_q^2 + i_d^2}} \quad (4)$$

$$\dot{\omega}_e = \frac{P}{2J} \left(T_t - \frac{3}{2} \frac{P}{2} \phi_m i_q \right) \quad (5)$$

$$\omega_e = \frac{P \omega_m}{2} \quad (6)$$

where

i_q is the quadrature current

i_d is the direct current

L is the inductance of the stator windings

R_s is the resistance of the stator windings

ω_e is the electrical angular speed

ϕ_m is the flux linked by the stator windings

v_s is the line voltage in the PMSG terminals

P is the number of poles

J is the inertia of the rotating system

T_t is the turbine torque

ω_e is the angular rotor speed.

The PV is modeled by the following equations [9]:

$$I = I_L - I_0 (e^{q(V+IR_s)/nkT} - 1) \quad (7)$$

$$I_{L(T_1)} = G * I_{SC(T_1, nom)} / G_{(nom)} \quad (8)$$

$$K_0 = (I_{SC(T_2)} - I_{SC(T_1)}) / (T_2 - T_1) \quad (9)$$

$$I_L = I_{L(T_1)} (1 + K_0(T - T_1)) \quad (10)$$

$$I_0 = I_{0(T_1)} * (T/T_1)^{3/n} * e^{-qV_g/nk * (1/T - 1/T_1)} \quad (11)$$

$$I_{0(T_1)} = I_{SC(T_1)} / (e^{qV_{OC(T_1)}/nkT_1} - 1) \quad (12)$$

$$R_s = -dV/dI_{V_{OC}} - 1/X_V \quad (13)$$

$$X_V = I_{0(T_1)} * q/nkT_1 * e^{qV_{OC(T_1)}/nkT_1} \quad (14)$$

where,

I_0 : saturation current for diode [A]

q : electronic charging [1.6e-19 C]

n : quality factor of diode

k : Boltzman's constant [1.38e-23 JK⁻¹]

T : temperature [°C]

T_1 : reference temperature-1 [°C]

T_2 : reference temperature-2 [°C]

G : irradiance [W/m²]

I_{sc} : short circuit current [A]

V_{oc} : open circuit voltage [V]

V_g : gap voltage band [V]

The battery model is shown in Fig. 1 and expressed in the following equations [10].




Fig. 1 Non-linear battery model [10].

$$E = E_0 - K \frac{Q}{Q - \int idt} + A \exp(-B \int idt) \quad (15)$$

$$V_{batt} = E - Ri$$

where

E = no load voltage

E_0 = battery constant voltage

K = polarization voltage

Q = battery capacity

$\int idt$ = actual battery charge

A = exponential zone amplitude

B = exponential zone time constant inverse

V_{batt} = battery voltage

R = internal resistance

i = battery current

2.2 Hybrid Power System Architecture




Fig. 2 Architecture of hybrid power system [11].

The architecture of hybrid power system is shown in Fig. 2. The hybrid power system consists of a solar panel and a wind power as energy resources, and a battery as the backup energy. They are connected to a DC bus which supplies energy to the load. Since the bus is DC, a DC to AC converter is required to convert the DC voltage to AC voltage required by the AC load.

2.3 Web SCADA System Design

In this work, the Web SCADA is implemented using IntegraXor software [7]. The SCADA configuration is shown in Fig. 3. The parameters of hybrid power system which are controlled and monitored by SCADA system are :

- Solar irradiation
- Temperature of PV
- Wind speed
- The current, voltage and power of PV
- The current, voltage and power of Wind energy system (WES)
- The current, voltage and power of load
- The current, voltage and power of DC bus
- The current, voltage and SOC of battery
- PV relay (connect/disconnect PV to DC bus)
- WES relay (connect/disconnect WES to DC bus)
- Load relay (connect/disconnect load to DC bus)
- Battery relay (connect/disconnect battery to DC bus)




Fig. 3 SCADA architecture.

The communication between IntegraXor and Matlab-Simulink is established via serial communication using Modbus protocol. The main contribution of the work is in the development of the Modbus interface using Simulink to communicate with SCADA system. Once the Modbus interface is developed in the Simulink, the hybrid power system which is modeled using Simulink could be accessed by external application like SCADA system.

The device configuration for SCADA system is done using IntegraXor editor as shown in Fig. 4. As shown in the figure, every parameter to be monitored and controlled is assigned with tag name and the address.




Fig. 4 Device configuration.

The other tasks should be configured in the IntegraXor editor are alarm, trending and report. The alarm management is used to give information to the operator when some of parameters exceed the desired limit. The trending displays a change of value of the parameters over the time. The reporting module provides the reports of the log data both for screen viewing and printout.

The graphical animation is created using Inkscape SAGE as shown in Fig. 5. This animation is used to control and monitor all parameters of hybrid power system.




Fig. 5 Graphical animation

3. Experimental Results

The proposed wind-PV-battery hybrid power system is implemented using Matlab-Simulink as shown in Fig. 6. The Simulink model consists of PV module, Wind energy system module, Battery module, Serial communication module, and Embedded Matlab function. The embedded Matlab function handles the Modbus communication between Simulink and SCADA software.

In the experiment, the hybrid power system is simulated during 600 seconds. To provide the real-time simulation, the Simulink Real Time Execution [12] is employed. Figure 7 shows the simulation results, where the first, second, third, and fourth figures represent the PV power, WES power, load power, and battery voltage respectively. During 0 to 100 second, the total power generated by WES and PV is greater than the load power. Therefore, the surplus energy is used to charge the battery. In this case, the battery voltage will be negative as shown in the figure. In the rest of the simulation time, the total power generated by WES and PV is lower than the load power. Therefore the battery will discharge to supply the load. In such situation, the battery voltage will be positive as shown in the figure.

The Web SCADA animation display is shown in Fig. 8. In the figure, the parameters of hybrid power system which is simulated using Simulink is displayed in the web browser. The control action to connect/disconnect WES, PV, load, and battery is indicated with On/OFF buttons. As shown in the figure, all the buttons are green to indicate that all components are connected to the bus. User could change the connection by pressing the respective button. Figure 9 shows the trending of WES. It is shown that the profile of power generated by wind energy system conforms with the one shown in Fig. 7.

4. Conclusions

The method to combine the real Web SCADA software and simulation model using Simulink is described. The proposed Web SCADA system is designed to control and monitor the parameters of wind-PV-battery power system. Both the Web SCADA software and Simulink could communicate in real time. The control action and monitoring operation of the SCADA system could work properly.

In future, the developed system will be expanded to include the sophisticated supervisory control system of

hybrid power system. Further, the more SCADA features will be implemented.

References

- [1] L. Wang and K.H. Liu, "Implementation of a Web-Based Real-Time Monitoring and Control System for a Hybrid Wind-PV-Battery Renewable Energy System", in International Conference on Intelligent Systems Applications to Power Systems, 2007, pp. 1-6.
- [2] K. Kim, G. Parthasarathy, O. Uluyol, W. Foslien, S. Sheng, P. Fleming, "Use of SCADA Data for Failure Detection in Wind Turbines", in Energy Sustainability Conference and Fuel Cell Conference, 2011.
- [3] F.R. Yu, P. Zhang, W. Xiao, P. Choudhury, "Communication Systems for Grid Integration of Renewable Energy Resources", IEEE Network, Vol. 25, No. 5, Pp. 22-29.
- [4] J.M.G. Figueiredo, J.M.G. Sa da Costa, "Intelligent Sun-Tracking System for Efficiency Maximization of Photovoltaic Energy Production", in International Conference On Renewable Energy and Power Quality, 2008.
- [5] R. Kirubashankar, K. Krishnamurthy, J. Indra, B. Vignesh, "Design and Implementation of Web Based Remote Supervisory Control and Information System", International Journal of Soft Computing and Engineering, Vol. 1, No. 4, 2011.
- [6] R. Fan, L. Cheded, O. Toker, "Internet-based SCADA: A new approach using JAVA and XML", Computing and Control Engineering Journal, Vol. 16, No. 5, pp. 22-26, 2005.
- [7] IntegraXor SCADA System. (<http://www.integraxor.com/>)
- [8] F. Valenciaga, P.F. Puleston, P.E. Battaiotto, "Power Control of a Solar/Wind Generation System Without Wind Measurement: A Passivity/Sliding Mode Approach", IEEE Transactions on Energy Conversion, Vol. 18, No. 4, pp. 501-507, 2003.
- [9] G R Walker, "Evaluating MPPT Converter Topologies Using A MATLAB PV Model", Journal of Electrical & Electronics Engineering, Vol. 21, No. 1, pp. 49-56, 2001.
- [10] O. Tremblay, L.A. Dessaint, A. Dekkiche, "A Generic Battery Model for the Dynamic Simulation of Hybrid Electric Vehicles", in Vehicle Power and Propulsion Conference, pp. 284-289, 2007.
- [11] A. Soetedjo, Y.I. Nakhoda, A. Lomi, M. Huda, "Supervisory Control for Hybrid Power System Using Smart Relay," in TEKNOIN Conference, 2012.
- [12] G. Rouleau, "Simulink Real Time Execution". (<http://www.mathworks.com/matlabcentral/fileexchange/21908-simulink%20AE-real-time-execution>)

Aryunto Soetedjo received the B.Eng. and the M. Eng. Degrees in Electrical Engineering from Bandung Institute of Technology, Indonesia in 1993 and 2002, respectively, and the Dr. Eng. degree in Information Science and Control Engineering from Nagaoka University of Technology, Japan in 2006. During 1994–2003, he worked in Traffic Control System R&D Department, Telnic Industries Co. Ltd. During 2006- 2008, He worked as lecturer in the Faculty of Engineering, Multimedia University, Malaysia. From 2008 until now, he is a lecturer in the Department of Electrical Engineering, National Institute of Technology (ITN) Malang, Indonesia. His main research interests are in image processing, machine learning, artificial intelligent, robotics, control systems, and renewable energy.

Abraham Lomi received his B. Eng. in Electrical Engineering from Institut Teknologi Nasional, Malang, Indonesia in 1987, his M. Eng. in Electrical Power Engineering from Institut Teknologi Bandung, Bandung, Indonesia in 1992 and his Doctor of Engineering in Electric Power Systems Management from the Asian Institute of Technology, Bangkok, Thailand, in 2000. He is currently a full Professor at the Department of Electrical Engineering, Institut Teknologi Nasional, Malang. Professor Lomi is a member of IEEE Power & Energy Society, USA and Indonesian Institute of Engineers. He was a Visiting Professor at the School of Information Technology and Electrical Engineering, the University of Queensland, Australia, 2011. His research interests include power system stability, power electronics, power quality and renewable energy.

Yusuf Ismail Nakhoda received his B. Eng. in Electrical Engineering from Institut Teknologi Nasional, Malang, Indonesia in 1987, his M. Eng. in Electrical Power Engineering from University of Indonesia in 2001. He is currently a lecturer at the Department of Electrical Engineering, Institut Teknologi Nasional, Malang. His main research are in renewable energy, computer aided design, and multimedia.

Yohan Pramono Tosadu currently is undergraduate student of Electrical Engineering, Institut Teknologi Nasional, Malang. He is doing the final project in the Web SCADA and computer networks.




Fig. 6 Simulink model of the hybrid power system.




Fig. 7 Simulation result




Fig. 8 Web SCADA animation display




Fig. 9 Trending of WES.